



Month	<b>Lift Station Inspection</b>	Year
APRIL		2021

Electric Meter 1590			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	19147		1325.52		1405.15				
4/8/21	19234	87	1328.02	2.50	1408.16	3.01	y y y y y		
4/15/21									
4/22/21	19430	283	1338.73	5.71	1413.68	5.52			
4/29/21	19527	380	1336.77	3.04	1416.64	2.96			
YTD		1970		11.25		11.49			

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
4/8/21	y	y	y	-	y	-	purge	x	x
4/15/21	y	y	-	-	y	-	purge	x	x
4/22/21	y	y	-	-	y	-	purge	x	x
4/29/21	y	y	-	-	y	-	purge	x	x

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
4/8/21	y	231.0	<del>1.2</del>	✓	✓	12.6	y	good	
4/15/21	y	231.3	1.3	✓	✓	-		good	
4/22/21	y	231.5	1.3	✓	✓	12.6		good	
4/29/21	y	231.7	1.2	✓	✓	12.8		good	

Meter Reading				Change Chart Y/N
Date	Current Read	Weekly Total	Daily Average	
Previous	239622390			
4/8/21	239808860	186,470 \ 7	26,639	y
4/22/21	240215890	407,030 \ 14	29,073	n
4/29/21	240431630	215,740 \ 7	30,820	y
Monthly Total		809,240 \ 28	28,901	

4/22 pump down #2 1m 15s  
 pump's meter numbers for 4/15/21 are lost combined with 4/15 & 4/22

ALC