

5/30

Month	Lift Station Inspection	Year
JUNE		2021

Electric Meter 2349			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	19906		1349.49		1428.94				
6/10/21	20015	109	1354.19	4.70	1433.51	4.57	Y		
6/25/21	20169	263	1360.98	6.79	1440.19	6.68	Y		
7/1/21	20226	320	1363.49	2.57	1442.64	2.45	Y		
YTD		2669		14.0		13.7			

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
6/10/21	Y	Y	N	-	Y	-	purged	Y	Y
6/25/21	Y	Y	N	-	Y	-	purged	Y	Y
7/1/21	Y	Y	N	-	Y	-	purged	Y	Y

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
6/10/21	Y	232.9	.4	✓	✓	12.8			
6/25/21	Y	233.3	.4	✓	✓	12.8			
7/1/21	Y	233.5	.2	✓	✓	12.6			

5/30 Meter Reading				Change Chart Y/N
Date	Current Read	Weekly Total	Daily Average	
Previous	241310250			
6/10/21	241628510	318,260	11	31,826
6/25/21	242036700	405,190	15	27,213
7/1/21	242210250	173,550	6	28,925
Monthly Total		900,000	32	28,125