

MONTHLY LIFT STATION REPORT

205TH SEWER LIFT STATION

MONTH September 2021 YEAR

DATES FROM: 8/26 - 10/1/21

NUMBER OF DAYS: 36

Reading: 244708270

Total Flow: 931,870

Average daily flow: 25,884

KW 369

KW Y.T.D.: 356

ADDED REPAIRS YES NO SEE ATTACHED

COMMENTS:

Replaced filter on pump #1
all other good

SIGNATURE Thy Willard

Month	Lift Station Inspection	Year
September		2021

Electric Meter 3193			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	20750		1388.49		1464.77				
9/2/21	20813	63	1391.31	2.82	1467.54	2.77	y		
9/10/21	20895	145	1394.23	2.92	1470.40	2.86	y		
9/16/21	20957	207	1396.64	2.41	1472.70		y		
9/23/21	21033	283	1399.37	2.73	1475.35		y		
10/1/21	21119	369	1402.23	2.86	1478.11		y		

YTD 3562

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
9/2/21	y	y	N	N	y	-	purge	✓	✓
9/10/21	y	y	N	N	y	-	change	✓	✓
9/16/21	y	y	N	N	y	-	purge	✓	✓
9/23/21	y	y	N	N	y	-	purge	✓	✓
10/1/21	y	y	N	N	y	-	purge	✓	✓

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
9/2/21	y	268.7	.2	✓	✓	12.7	-	good	
9/10/21	y	268.9	.2	✓	✓	12.6	-	good	
9/16/21	y	269.1	.2	✓	✓	12.8	-	good	
9/23/21	y	269.3	.2	✓	✓	12.6	-	good	
10/1/21	y	269.5	.2	✓	✓	12.7	-	good	

Meter Reading				Change Chart Y/N
Date	Current Read	Weekly Total	Daily Average	
Previous	243776440			
9/2/21	243960090	183,650	7	26,236
9/10/21	244162110	202,020	8	25,253
9/16/21	244320070	157,960	6	26,327
9/23/21	244507480	187,410	7	26,772
10/1/21	244708270	200,790	8	25,099
Monthly Total		931,830		25884