

MONTHLY LIFT STATION REPORT

205<sup>TH</sup> SEWER LIFT STATION

MONTH January 2022 YEAR

DATES FROM: 12/31/21 - 2/3/22

NUMBER OF DAYS: 34

Reading: 248 331 120

Total Flow: 1,104,980

Average daily flow: 32,499

KW 648

KW Y.T.D.: ~~5527~~ 648

ADDED REPAIRS YES SEE ATTACHED  
 NO

**COMMENTS:**  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

SIGNATURE Thy Nelson

Scan

Month	<b>Lift Station Inspection</b>	Year
JANUARY		2022

Electric Meter 4881			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	22438		1479.57		1514.47				
1/4/22	22504	66	1441.39	1.82	1576.13	1.66	Y		
1/13/22	22679	241	1445.75	4.36	1520.39	4.26	Y		
1/21/22	22836	398	1449.59	3.84	1524.13	3.74	Y		
2/3/22	23086	648	1455.80	6.21	1530.13	6.00	Y		
YTD		✓ 5							

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
1/4/22	Y	Y	N	N	Y	-	Purged	✓	✓
1/13/22	Y	Y	N	N	N	-	Purged	✓	✓
1/21/22	Y	Y	N	N	Y	-	Purged	✓	✓
2/3/22	Y	Y	N	N	Y	-	Purged	✓	✓

<b>Standby Generator</b>									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
1/4/22	Y	272.3	.2	✓	✓	12.7	N	good	
1/13/22	Y	272.5	.2	✓	✓	12.8	N	good	
1/21/22	Y	272.7	.2	✓	✓	14.7	N	good	
2/3/22	Y	273.1	.4	✓	✓	12.7	N		

Meter Reading				Change Chart Y/N	
Date	Current Read	Weekly Total	Daily Average		
Previous	247226140				
1/4/22	247341620	115,480	4	28,870	Y
1/13/22	247627910	286,290	9	31,810	N
1/21/22	247892600	264,690	8	33,086	Y
2/3/22	248331120	438,520	3	33,732	N
Monthly Total		1,104,980	34	32,499	