

MONTHLY LIFT STATION REPORT

205th SEWER LIFT STATION

MONTH	June	2023	Year
Dates From:	5.27.23 thru 6.29.23		
Number of Days:	33		
Reading:	263137600		
Total Flow:	863660		
Average Daily Flow:	26244		
Kilowatts For Month:	417		
Kilowatts YTD:	2640		
ADDED REAIRS	Yes No	SEE ATTACHED	

COMMENTS:

SIGNATURE:

Thos W. Malone

Scan ✓

Month	Lift Station Inspection	Year
June		2023

Electric Meter		2223	Pump Hours				Ran Pumps	Motor Amp Draw	
Date	Read	Total	#1	Hours	#2	Hours	Y/N	Pump 1	Pump 2
Previous	29411		1661.24		1729.99				
6.6.23	29484	73	1665.32	4.08	1734	4.01	y	na	na
6.13.23	29552	68	1667.9	2.58	1736.62	2.62	y	na	na
6.22.23	28595	43	1671.43	3.53	1739.91	3.29	y	na	na
6.29.23	29644	233	1674.19	2.76	1742.55	2.64	y	na	na
		417		12.95		12.56			

Date	Fan OK Y/N	Dialer OK Y/N	heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filter	Exercise Valves	
								#1	#1
6.6.23	y	y	n	n	n	na	purged	y	y
6.13.23	y	y	n	n	n	na	purged	y	y
6.22.23	y	y	n	n	n	na	purged	y	y
6.29.23	y	y	n	n	y	na	purged		
0									

Standby Generator									
Date	Automatic Run as Scheduled	Hour 290.3	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
6.6.23	y	290.9	0.6	y	y	12.6	n	good	
6.13.23	y	291.1	0.2	y	y	12.8	n	good	
6.22.23	y	291.1	0	y	y	12.9	n	good	
6.29.23	y	291.3	0.2	y	y	12.7	y	good	
0			1						

Meter Reading						Change Chart Y/N	
Date	Current Read	Weekly Total	Days	Daily Average			
Previous	262273940						
6.6.23	262548110	274170	10	27417		n	
6.13.23	262748555	200445	7	28635		y	
6.22.23	262958120	209565	9	23285		n	
6.29.23	263137600	179480	7	25640		y	
0							
Monthly Total		863660	33	26244			

slon