

# MONTHLY LIFT STATION REPORT

## 205th SEWER LIFT STATION

MONTH	July	2023	Year
Dates From:	6/29 thru 8/1		
Number of Days:	33		
Reading:	263990420		
Total Flow:	852820		
Average Daily Flow:	25673		
Kilowatts For Month:	471		
Kilowatts YTD:	2694		
ADDED REAIRS	Yes	x	SEE ATTACHED
	No		

### COMMENTS:

7/27. #1 pump lube line filter housing, plastic nut on valve cracked and would not tighten.

made temporary repair will be ordering parts or a replacement.

SIGNATURE:

*Thomas Michael*

*Pay Troy  
for this extra  
call out  
in Sept.  
7 EPTS was paid  
on ch # 4384  
8/1/23*

Month	Lift Station Inspection	Year
July		2023

Electric Meter		2223	Pump Hours				Ran Pumps	Motor Amp Draw	
Date	Read	Total	#1	Hours	#2	Hours	Y/N	Pump 1	Pump 2
Previous	29411		1674.19		1742.55				
7.13.23	29573	162	1680.56	6.37	1748.79	6.24	y		
7.25.23	29793	220	1683.07	2.51	1751.29	2.5	y		
8.1.23	29882	89	1687.96	4.89	1756.07	4.78	y		
		471		13.77		13.52			

Date	Fan OK Y/N	Dialer OK Y/N	heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filter	Exercise Valves #1 #1	
7.13.23	y	y	n	n	y	na	purge	y	y
7.25.23	y	y	n	n	n	na	change	y	y
8.1.23	y	y	n	n	n	na	purge	y	y
0									
0									

Standby Generator									
Date	Automatic Run as Scheduled	Hour 291.3	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
7.13.23	y	291.7	0.4	y	y	12.7	n	good	
7.25.23	y	291.9	0.2	y	y	12.6	n	good	
8.1.23	y	292.3	0.4	y	y	12.6	y	good	
0			-292.3						
0			-291.3						

Meter Reading					Change Chart Y/N	
Date	Current Read	Weekly Total	Days	Daily Average		
Previous	263137600					
7.13.23	263513640	376040	14	26860	y	
7.25.23	263815263	301623	12	25135	y	
8.1.23	263990420	175157	7	25022	n	
0						
0						
<b>Monthly Total</b>		852820	33	25673		

Scan