

MONTHLY LIFT STATION REPORT

205<sup>TH</sup> SEWER LIFT STATION

MONTH October 2021 YEAR

DATES FROM: 10/1/21 - 10/31/21

NUMBER OF DAYS: 30 days

Reading: 245 496 980

Total Flow: ~~788~~ 710

Average daily flow: 26,290

KW 358

KW Y.T.D.: 3562

ADDED REPAIRS      YES      SEE ATTACHED  
                                 NO

COMMENTS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

SIGNATURE Tracy Hill

Month	<b>Lift Station Inspection</b>	Year
October		2021

Electric Meter 3562			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	21119		1402.27		1478.11				
10/8/21	21190	71	1404.82	2.59	1480.62	2.51	Y		
10/18/21	21308	189	1409.32	4.50	1484.97	4.35	Y		
10/22/21	21352	237	1411.07	1.75	1486.67	1.70	Y		
10/31/21	21477	358	1414.43	3.36	1489.94	3.27	Y		
	YTD	3920							

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
10/8/21	Y	Y	N	Y	Y	-	purge	Y	Y
10/18/21	Y	Y	N	Y	N	-	purge	Y	Y
10/22/21	Y	Y	N	Y	Y	-	change	Y	Y
10/31/21	Y	Y	N	Y	N	-	purge	Y	Y

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
10/8/21	Y	269.7	2	✓	✓	12.6	Y	good	
10/18/21	Y	270.1	4	✓	✓	12.7	N	good	
10/22/21	Y	270.8	8	✓	✓	14.1	N	good	
10/31/21	Y	270.5	4	✓	✓	12.7	N	good	

Date	Meter Reading			Change Chart Y/N
	Current Read	Weekly Total	Daily Average	
Previous	244708270			
10/8/21	244883290	175,020	25,002	Y
10/18/21	245162060	278,770	27,877	N
10/22/21	245261390	99,330	24,833	Y
10/31/21	245492480	235,590	26,176	N
Monthly Total		788,710	26,290	