

Month	Lift Station Inspection	Year
January		2023

Electric Meter		Pump Hours					Ran Pumps	Motor Amp Draw	
Date	Read	Total	#1	Hours	#2	Hours	Y/N	Pump 1	Pump 2
Previous	27188		1600.91		1671.18				
1.10.23	27338	150	1605.29	4.38	1675.49	4.31	y		
1.17.23	27450	112	1608.09	2.8	1678.22	2.73	y		
1.26.23	27601	151	1611.8	3.71	1681.83	3.61	y		
2.1.23	27715	114	1614.56	2.76	1684.53	2.7	y		
		527		13.65		13.35			

Date	Fan OK Y/N	Dialer OK Y/N	heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filter	Exercise Valves	
								#1	#1
1.10.23	y	y	n	n	y	na	purge	y	y
1.17.23	y	y	n	n	n	na	change	y	y
1.26.23	y	y	n	n	n	na	purge	y	y
2.1.23	y	y	n	n	n	na	purge	y	y
0									

Standby Generator									
Date	Automatic Run as Scheduled	Hour 286.1	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
1.10.23	y	286.5	0.4	y	y	12.9	n	good	
1.17.23	y	286.7	0.2	y	y	12.8	n	good	
1.26.23	y	286.9	0.2	y	y	12.8	n	good	
2.1.23	y	287.1	0.2	y	y	12.9	n	good	
0			1						

Meter Reading					Change Chart Y/N	
Date	Current Read	Weekly Total	Days	Daily Average		
Previous	258101740					
1.10.23	258380020	278280	9	30920	y	
1.17.23	258583730	203710	7	29101	n	
1.26.23	258847950	264220	9	29358	y	
2.1.23	259035750	187800	6	31300	n	
0						
Monthly Total		934010	31	30170		

Scan