

Month	Lift Station Inspection	Year
July		2022

Electric Meter			Pump Hours				Ran Pumps	Motor Amp Draw	
Date	Read	Total	#1	Hours	#2	Hours	Y/N	Pump 1	Pump 2
Previous	25193		1520.35		1592.61				
7.8.22	25265	72	1523.66	3.31	1595.84	3.23	Y		
7.14.22	25325	132	1526.34	2.68	1598.5	2.66	Y		
7.21.22	25392	199	1529.75	3.41	1601.85	3.35	Y		
7.29.22	25461	268	1532.53	2.78	1604.57	2.72	Y		

Date	Fan OK Y/N	Dialer OK Y/N	heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filter	Exercise Valves	
								#1	#1
7.8.22	Y	Y	N	N	Y		Purged	Y	Y
7.14.22	Y	Y	N	N	N		Changed	Y	Y
7.21.22	Y	Y	N	N	N		Purged	Y	Y
7.29.22	Y	Y	N	N	N		Changed	Y	Y

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
7.8.22	Y	279.7	0.2	x	x	12.7	N	good	
7.14.22	Y	279.9	0.2	x	x	12.6	N	good	
7.21.22	Y	280.1	0.2	x	x	12.7	N	good	
7.29.22	Y	280.3	0.2	x	x	14.1	N	good	

Meter Reading				Change Chart Y/N	
Date	Current Read	Weekly Total	Daily Average		
Previous	252873240				
7.8.22	253089820	216580	27073		
7.14.22	253253120	163300	27217		
7.21.22	253446070	192950	27564		
7.29.22	253657040	210970	26371		
Monthly Total		783800	27027		

KW - year to date 2746
 scan ✓

