

GREEN TOWNSHIP LIFT STATION SYSTEM CLIENT REPORT JULY 2024

To provide Green Township with a summary of our activities for the month of July, Operations Services has prepared this report for your use. We welcome any suggestions to improve the information contained in these reports. Please contact us if you believe this report contains errors, or if you have any questions about it.

LIFT STATION SYSTEM MONTHLY ACTIVITY SUMMARY

The following is a list of activities that were performed during the monthly lift station inspection on 7/18/24:

- Noted current generator run time
- Inspected main control panel
- Ran both lift station pumps in hand to verify proper pump operation
- Checked inside and in the surrounding area of the wet well for any garbage or debris around the lift station
- Performed visual inspection of the check valve pit
- Cleaned the seal filters
- No grease or debris observed in the wet well
- Tested floats for proper operation
- Verified all lights are functional
- Performed inspection of the exhaust fan
- Inspected all ladders and the heater
- Tested amp draws on both pumps (data below)
- Checked generator and verified it is operational
- One service call on 7/18 for a failed transducer. Hooked up the backup floats while on site.

Pump No.1 and Pump No. 2 Monthly Amp Draw Data:

Amp Draws	Pump No. 1	Pump No. 2
L1	29	22
L2	28	24
L3	26	27

Activity logs of all activity at the lift station are noted by operators and input into our cloud-based software. The following is a snapshot of where the lift station data is stored:

View 2024 Green Township Lift Station ☆					
DAY/DATE	PUMP 1: AMP DRAW L1 (MONTHLY CHECK)	PUMP 1: AMP DRAW L2 (MONTHLY CHECK)	PUMP 1: AMP DRAW L3 (MONTHLY CHECK)	PUMP 2: AMP DRAW L1 (MONTHLY CHECK)	PUMP 2: AMP DRAW L2 (MONTHLY CHECK)
TOTAL					
Thu 07/18/2024	29	28	26	22	24
MINIMUM					

If you have any questions, please feel free to contact me directly.

Thank you,

Julie LaFond
Project Manager
(810) 599-5598
jlafond@operationservices.com