

MONTHLY LIFT STATION REPORT

205TH SEWER LIFT STATION

MONTH January 2021 YEAR

DATES FROM: 12/30/20 - 1/29/21

NUMBER OF DAYS: 30 days

Reading: 237 609436

Total Flow: 919,086

Average daily flow: 30,636

KW 517

KW Y.T.D.: 517

ADDED REPAIRS YES SEE ATTACHED
~~NO~~

COMMENTS:

SIGNATURE *Thy Kell-ed*

Month	Lift Station Inspection	Year
JANUARY		2021

Electric Meter			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	17557		1285.03		1366.59				
1/7/21	17694	137	1288.65	3.62	1370.11	3.52	Y	-	-
1/14/21	17814	257	1291.83	3.18	1373.19	3.08	Y	-	-
1/23/21	17966	409	1295.54	3.71	1376.77	3.58	Y	-	-
1/29/21	18074	517	1298.10	2.56	1379.24	2.47	Y	-	-
YTD		517		13.67		12.65			

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprng/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
1/7/21	Y	Y	N	-	✓	-	purge	✓	✓
1/14/21	Y	Y	N	-	✓	-	purge	✓	✓
1/23/21	Y	Y	N	-	✓	-	purge	✓	✓
1/29/21	Y	Y	N	-	✓	-	purge	✓	✓

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
1/7/21	Y	228.2	.2	✓	✓	12.8	Y	good ↑	
1/14/21	Y	228.5	.2	✓	✓	12.8	N		
1/23/21	Y	228.17	.2	✓	✓	12.6	N		
1/29/21	Y	228.9	.2	✓	✓	12.8	N		

Meter Reading				Change	
Date	Current Read	Weekly Total	Daily Average	Chart Y/N	
Previous	236690350				
1/7/21	236,942,582	252,232 8	31,529	Y	
1/14/21	237158790	216,208 7	30,887	N	
1/23/21	237426020	267,230 9	29,692	Y	
1/29/21	237609436	183,416 6	30,569	N	
Monthly Total		919,086 70	30,636		